


**Notes**

- The existing 4 inch water main in Higuera Street shall be replaced with a 10 inch main between Osos and Court Streets.
- The existing 6 inch water main in Monterey Street shall be replaced with a 10 inch main between Osos and Court Streets.
- New/replacement hydrants shall be provided as required to assure adequate fire flow to the project, to the approval of the Utilities Engineer and the Fire Marshal.
- The Fire Department connection for the Anderson Hotel on Court Street shall be relocated and/or connected to the service on the Monterey Street Frontage, to the approval of the Fire Marshal.
- Traffic control systems such as the "Opticom" priority control system shall be installed at downtown intersections as required to improve emergency response to the project, to the approval of the Fire Marshal.
- Two additional mobile telephone units such as "Smartnet" units shall be provided to improve emergency response to the project, to the approval of the Fire Marshal.

**OSOS STREET**



**NORTH**  
SCALE 1/8" = 1'-0"